

Reversible integrating counter with calculation function

# DT-601CG

## Operation Manual

Read this manual thoroughly prior to usage.

Use this instrument only after reading the manual completely. Follow all safety precautions.



A **Nidec** Group Company

**SHIMPO** All for dreams

## Safety Precautions.

Please be sure to follow all safety precautions closely.

Be sure to read the entire instruction manual thoroughly before initial set-up, operation and maintenance.

This instruction manual provides two grades of safety warnings: "Danger" and "Caution".  
Be sure to follow these precautions.



Misusing or disregarding the instructions with this mark might cause death, severe injury, or fire.



Misusing or disregarding the instructions might cause property damage or minor injury. However, depending on the situation, it might lead to greater outcome.

Below are the explanations of each cautions to be followed.



The act indicated by this sign is strictly prohibited.



The act indicated by this sign must be executed by no means.



### Caution



NEVER EXCEED SPECIFIED VOLTAGE



NEVER EXCEED RATED LOAD



AVOID DIRECT SUNLIGHT



DO NOT USE IN THE PLACE WITH  
FLAMMABLE OBJECTS AND GAS



AVOID HUMIDITY AND CONDENSATION



DO NOT DROP OR SHAKE



AVOID CONTAMINATION



KEEP AWAY FROM ELECTRIC WIRE.



BE CAREFUL NOT TO GET  
ELECTROCUTED



DO NOT TOUCH TERMINALS WHILE THE  
POWER IS ON.



DO NOT DISSEMBLE OR TOUCH  
INTERNAL PARTS WHILE THE POWER IS  
ON

## OPTION NAME

| Model name | Disp - lay | 90° Input | Output | Input | Sensor power supply | power supply | function                                                                                                    |
|------------|------------|-----------|--------|-------|---------------------|--------------|-------------------------------------------------------------------------------------------------------------|
| DT-601CG   |            |           |        |       |                     |              | Alarm output : Two-points NPN output : OUT 1,2<br>Alarm output : Two-points PhotoMOS relay output : OUT 3,4 |
|            | Blank      |           |        |       |                     |              | 7 segments LED (RED)                                                                                        |
|            |            | RE        |        |       |                     |              | 90° phase contrast input                                                                                    |
|            |            | RE-2T     |        |       |                     |              | 90° phase contrast input (Input two multiplying)                                                            |
|            |            | RE-4T     |        |       |                     |              | 90° phase contrast input (Input four multiplying)                                                           |
|            |            |           | AV3    |       |                     |              | Analog electric voltage output (DC1-5V, 5V-1V)                                                              |
|            |            |           | AV4    |       |                     |              | Analog electric voltage output (DC0-5V, 5V-0V)                                                              |
|            |            |           | AV5    |       |                     |              | Analog electric voltage output (DC0-10V, 10V-0V)                                                            |
|            |            |           | AI     |       |                     |              | Analog electric current output (DC4-20mA, 20-4mA)                                                           |
|            |            |           |        | B*    |                     |              | BCD output                                                                                                  |
|            |            |           |        | BI*   |                     |              | BCD input                                                                                                   |
|            |            |           |        | Blank |                     |              | NPN Open collector pulse input                                                                              |
|            |            |           |        | F     |                     |              | Electric voltage pulse input                                                                                |
|            |            |           |        | V3    |                     |              | Sinusoidal input                                                                                            |
|            |            |           |        | N     |                     |              | Sine curve input                                                                                            |
|            |            |           |        | L1    |                     |              | Line receiver input, Single phase input                                                                     |
|            |            |           |        | L2    |                     |              | Line receiver input, Double phase input                                                                     |
|            |            |           |        |       | HI                  |              | High speed input (0.01Hz-120kHz)                                                                            |
|            |            |           |        |       | Blank               |              | DC12V stabilization                                                                                         |
|            |            |           |        |       | S24                 |              | DC24V stabilization                                                                                         |
|            |            |           |        |       |                     | Blank        | AC Power source (AC85-264V)                                                                                 |
|            |            |           |        |       |                     | DC           | DC Power source (DC12-24V)                                                                                  |

\*Option B and Option B1 cannot be chosen simultaneously.

### About model type

e.g1) Choose analog electric current output, electric voltage pulse input and DC power supply.  
Model type will be **DT-601CG-AI-F-DC**

e.g2) Choose analog voltage output (0 to 5V), 90° phase contrast input, sensor power supply DC24V.  
Model type will be **DT-601CG-RE-AV4-S24**


| INDEX                                                            |      |                                     |
|------------------------------------------------------------------|------|-------------------------------------|
|                                                                  | PAGE | PAGE                                |
| 1. Summary                                                       | 2    | 17. BCD output 48                   |
| 2. Specification                                                 | 4    | 18. BCD input 49                    |
| 3. Meter installation                                            | 6    | 19. Outline dimensional drawing 50  |
| 4. Names and functions of each parts in the front.               | 7    | 20. Terminal block label drawing 51 |
| 5. Connecting terminal block                                     | 9    | 21. Unit label drawing 52           |
| 6. Format of input circuit                                       | 12   | 22. Packing specifications 53       |
| 7. Format of output circuit                                      | 13   | 23. About noise protection 54       |
| 8. Setting up the dip switch                                     | 14   | 24. Trouble shooting 55             |
| 9. Setting menu                                                  | 15   |                                     |
| 10. Initially set value and initialization                       | 16   |                                     |
| 11. Contents of each mode and setting                            | 17   |                                     |
| 12. Setting of preset value                                      | 43   |                                     |
| 13. Setting of display offset value                              | 44   |                                     |
| 14. Mode protect function                                        | 45   |                                     |
| 15. Adjusting analog output                                      | 46   |                                     |
| 16. Sensitivity setting of sinusoidal input and sine curve input | 47   |                                     |

## 1. SUMMARY

This instrument is a Reversible integrating counter with calculation function


### <Timing chart of each preset output operation>

#### (1) +2stages preset operation



#### (2) ±Each 1stage preset operation

##### <Boosting/Down operation>





Setting condition

Up/Down, and Automatic reset setting will be invalid

OFFSET = 0 , OFFSET < 0 , PRESET B < OFFSET < PRESET A

### (3) Batch count operation





#### Setting condition

Automatic reset selection and re-output selection will be invalid

OFFSET = 0, OFFSET < PRESET A,  
PRESET B > 0

PRESET A = 0, PRESET A < OFFSET,  
PRESET B > 0

### (4) +1stage plus secondary output operation



#### Setting condition

Re-output selection will be invalid.

OFFSET = 0, OFFSET < PRESET A,  
 $99.9 \geq \text{PRESET B} \geq 0$

PRESET A = 0, OFFSET > PRESET A ,  
 $99.9 \geq \text{PRESET B} \geq 0$

#### <Output condition of each preset output>

In principle, 1 shot or continuous shot will be output from OUT1 to OUT4 under the condition of "count display  $\geq$  ( $\leq$ ) Preset A (Preset B)

However, if +2stages preset operation or  $\pm 1$ stage preset operation was chosen, and used with the condition of "with re-output" or "without automatic reset", the condition will be as below irrespectively of the mode chosen (UP/DOWN).

Output set ON (continuous, 1 shot) :

Count display  $\leq (\geq)$  Preset A(Preset B)

Output set OFF (continuous, 1 shot\*) :

Count display  $< (>)$  Preset A(Preset B)

\* choosing 1shot makes output "ON"

## 2. SPECIFICATIONS

### [Standard]

|                    | ITEM                              | SPECIFICATIONS                                                                                                                                                                                                                                                                                      |
|--------------------|-----------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Integrated display | Scaling                           | 1x10 <sup>-9</sup> to 9999 (selectable)                                                                                                                                                                                                                                                             |
|                    | Accuracy                          | ±0 (when the scaling is set to 1)                                                                                                                                                                                                                                                                   |
|                    | Display                           | Six digits LED (characters are 14mm high and RED)                                                                                                                                                                                                                                                   |
|                    | Display Switch                    | Display 1 : D1 LED (green) is on, Display 2 : D2 LED(green)<br>(Change with ENT key)                                                                                                                                                                                                                |
|                    | Display Range                     | -99999 to 999999                                                                                                                                                                                                                                                                                    |
|                    | overscale Display                 | 3rd round stop (exceed the value three time, 999999 or -999999 will blink<br>Choose from "endless" or "display the number of time value exceeds"<br>(while pressing the XXX key, top 2digits will be displayed)                                                                                     |
|                    | Number of decimal setting         | Selectable up to thousandth                                                                                                                                                                                                                                                                         |
|                    | Reset                             | Hit RST key in the front part or input reset at terminal block.<br>(depending on the mode, select reset display)                                                                                                                                                                                    |
|                    | Display offset                    | By setting the display offset value,<br>display value after reset can be chosen from -99999 to 999999                                                                                                                                                                                               |
| Sensor Input       | Input signal                      | NPN open collector pulse input (minimum 10mA), or dry contact                                                                                                                                                                                                                                       |
|                    | Option : Type F                   | Electric voltage pulse input (LOW<2V, HI=3.8 to 30V)                                                                                                                                                                                                                                                |
|                    | Option : Type V3                  | Sinusoidal input                                                                                                                                                                                                                                                                                    |
|                    | Option : Type N                   | Sine curve input                                                                                                                                                                                                                                                                                    |
|                    | Option : Type L1                  | Line receiver 1phase                                                                                                                                                                                                                                                                                |
|                    | Option : Type L2                  | Line receiver 2 phase                                                                                                                                                                                                                                                                               |
|                    | Sensor input respond              | However, duty is 50% (change with dip switch)                                                                                                                                                                                                                                                       |
|                    | Option : Type HI                  | High speed input                                                                                                                                                                                                                                                                                    |
|                    | Sensor power supply               | (stabilization) output                                                                                                                                                                                                                                                                              |
|                    | Option : Type S24                 | (stabilization) output                                                                                                                                                                                                                                                                              |
| External Input     | Reset Input                       | Terminal block(4-3) to be ON more than 50ms<br>(accept NPN open collector pulse output or actual contact output)                                                                                                                                                                                    |
|                    | Hold selection input              | Select from Forbidden, Hold, Lap count, display exchange<br>Forbidden, Hold can be activated while terminal block(2-3) is ON. Toa<br>To activate Lap count and display change, turn the terminal block(2-3)<br>more than 50ms.<br>(accept NPN open collector pulse output or actual contact output) |
| Preset Output      | Output terminal/ style (OUT 1, 2) | Output from terminal block 9-6(OUT1) and 10-6(OUT2)<br>(6 is GND common) (However, with the line receiver, it will not function)<br>Two-points NPN open collector pulse output. Maximum rating<br>: DC30V 50mA                                                                                      |
|                    | Output terminal/ style (OUT 3,4)  | Output from terminal block 15-16(OUT3) and 17-18(OUT4)<br>Two-points PhotoMOS relay "a" contact output. Rated load current<br>: 0.12A Load voltage: AC140V                                                                                                                                          |
|                    | Preset operation                  | Selectable from + side 2stages,<br>± 1stage, batch count and +1stage secondary output                                                                                                                                                                                                               |
|                    | Output mode                       | Selectable from 1shot or continuous                                                                                                                                                                                                                                                                 |
|                    | 1shot period                      | Selectable from xxxxx                                                                                                                                                                                                                                                                               |
|                    | Preset value setting              | Selectable from -99999 to 999999. When delaying the secondary output,<br>selectable from 0.0 to 99.9. (the value outside the range is invalid)                                                                                                                                                      |
|                    | Output timing                     | Judge by comparing display value and preset value                                                                                                                                                                                                                                                   |
|                    | Output display                    | During the OUT1 alarm output is on,<br>OUT 1 LED (RED) will be synchronously flushing                                                                                                                                                                                                               |
|                    | Output reset                      | Activate by RST key in the front part or ,<br>making terminal reset input ON more than 50ms                                                                                                                                                                                                         |
|                    | Batch count display               | Display range is 0 to 999999 when selecting batch count operation<br>or pressing Shift key (when it exceeds, 999999 will be flushing)                                                                                                                                                               |
|                    | Others                            | Selecting UP/DOWN mode, automatic reset re-output can be set.                                                                                                                                                                                                                                       |



|        |                       |                                                                                                                                                    |
|--------|-----------------------|----------------------------------------------------------------------------------------------------------------------------------------------------|
| Others | Mode Protect function | Activate by Key operation (mode setting cannot be changed)                                                                                         |
|        | Data backup           | Write the each mode's set value and calculation value on to FRAM.<br>(over writing should be less than 10million times,about 10years conservation) |
|        | Power source          | AC85 - 264V ( 50 / 60Hz )                                                                                                                          |
|        | Option : DC type      | DC12 - 24V ( $\pm 10\%$ )                                                                                                                          |
|        | Operating humidity    | 0 - 50℃, 30 - 80%RH (non condensing)                                                                                                               |
|        | Weight, dimensions    | 400g W96xH48xD130mm ( W3.78"xH1.89"xD5.12" )                                                                                                       |
|        | Case material         | Chassis: mixed with ABS resin glass Terminal block                                                                                                 |
|        | Body color            | Black                                                                                                                                              |
|        | Protection grade      | IP66 equivalent                                                                                                                                    |
|        | Accessory             | Terminal block cover 2pcs : main body attachment (material: acrylic, transparent), Rubber packing (material: NBR, black), Unit rebel               |

#### [Option specification]

##### <Analog output : AV/VI option>

|               |                           |                                                                                                                                                                                                                                                                                            |
|---------------|---------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Analog output | Output terminal           | From terminal block 19-20                                                                                                                                                                                                                                                                  |
|               | Electric voltage output   | Load resistance more than xxx                                                                                                                                                                                                                                                              |
|               | Electric current output   | Load resistance less than xxx                                                                                                                                                                                                                                                              |
|               | Output accuracy           | Within $\pm 0.3\%$ (23℃) against displayed value (absolute value)                                                                                                                                                                                                                          |
|               | Temperature               | +100ppm/℃                                                                                                                                                                                                                                                                                  |
|               | Output respond            | about 50ms ( as a duration to reach 90% output change)                                                                                                                                                                                                                                     |
|               | Maximum output resolution | 12bit, D/A conversion system 4000 resolution<br>*maximum output range: up to 102.4% of each output's maximum value.<br>*with analog output, calculation is done against the displayed value with 7-segments LED. This might lower the resolution below 4000 depending on the mode setting. |
|               | Reverse output            | Reverse the electric voltage output(AV3-5) and electric current output (AI).<br>*With reverse output, maximum resolution is 4000 for each output style.                                                                                                                                    |

##### <BCD output : Option B>

|            |                         |                                                        |
|------------|-------------------------|--------------------------------------------------------|
| BCD Output | Output terminal         | From BCD option collector (37pin)                      |
|            | Output style            | Whole digit parallel, NPN open collector pulse output  |
|            | Output timing           | Synchronized with the display refresh                  |
|            | Output action           | With the output level "H", shunt with GND              |
|            | TI (Ban-loading) signal | Output with about 25ms width when data is refreshed    |
|            | Output logic            | Data value and TI signal, positive/negative selectable |
|            | Rating                  | DC30V, 10mA Max.                                       |
|            | Accessory               | D-sub37 pin male (soldered type) and connector hood    |


##### <BCD input : Option BI>

|           |                |                                                                     |
|-----------|----------------|---------------------------------------------------------------------|
| BCD Input | Input terminal | From BCD option connector (37pin)                                   |
|           | Input style    | Whole digit parallel, NPN open collector pulse input                |
|           | Input timing   | With calculation cycle                                              |
|           | Input action   | Shunt the necessary digit's terminals with GND.                     |
|           | Latch signal   | while inputting latch signal, data loading is prohibited            |
|           | Input logic    | Data value, latch signal, positive/negative selectable              |
|           | Rating         | outflow electricity is about 3mA when shunting each input terminals |
|           | Accessory      | D-sub37 pin male (soldered type) and connector hood                 |


### 3. METER INSTALLATION

(1) Cut the panel and insert the meter from the front part.


\* When you need a splash proof,  
insert the attached splash proof packing between meter and installation panel.



(2) Insert the attachment lugs in both sides of the meter.



(3) Slide the attachment lugs to the back (towards the terminal block side), and turn the screw to steady the meter. (both sides)




**NOTE :**

1. Make sure to horizontally installed
2. Panel has to be 1.0mm to 4.0mm thick.
3. Do not tighten the screw too much. The case might break.



#### 4. NAMES AND FUNCTIONS OF EACH PARTS IN THE FRONT.



##### (1) Display (A to F)

- While measuring : Indicate the measured value of Display 1(D1) or Display 2(D2)
- While setting : While setting modes, Display A and B indicate mode number and C to F indicate setting value
- : While setting preset value, display indicates current value
- : While setting the display offset value, display indicates current value

##### (2)-(5) OUT1- 4 Alarm output LED

Synchronously flash when the OUT1 to 4's alarm was output

##### (6) Overscale LED

Flash when the value exceed 999999 or below -99999.

##### (7) Hold LED

Flash when there is external input (shunt terminal block #2 and #3)

##### (8) Mode Key Mode

- While turning on : TEST mode is activated when power is turned on while pressing this key (To escape from TEST mode, turn off the power)
- While measuring : Mode setting is activated when Shift key is pressed more than 2seconds while pressing this key.
- : Preset value setting is activated when the key is pressed more than 2seconds.
- : Display offset value setting is activated when Up key is pressed more than 2seconds while pressing this key.
- While setting : Mode number (Display A, B) can be changed over
- : While setting preset value, preset number (PRESET A to B) can be switched over.

---

**(9) Shift key** 

- While measuring : Activate the mode setting (press with the mode key more than 2seconds)  
Batch count number will be displayed while pressing this key.  
(while selecting batch count mode)
- While setting : Shift the decimal place towards right hand side.

**(10) Up key** 

- While measuring : Activate display offset value (press with the mode key more than 2seconds)  
While pressing this key, number of times exceeded the limit is indicated.
- While setting : Change the value while setting (UP side)

**(11) Down key** 

- While setting : Change the value while setting (DOWN side)  
: Activate or modify mode protect function

**(12) Enter key** 

- While turning on : Format the each set values by turning on while pressing this key
- While measuring : Change the display from Display 1(D1) and Display 2(D2)
- While setting : While setting, value will be registered with this key and return to the measuring display

**(13) Reset key** 

- While measuring : Switch back the display to "ZERO" or cancel the alarm output  
Switch back the batch count display to "ZERO"
- While setting : While setting, value will not be registered with this key and return to the measuring display.

**(14) Display 1 LED**

Will flash when displaying the value of Display1 (D1)


**(15) Display 2 LED**

Will flash when displaying the value of Display2 (D2)

\* D1 and D2 is the one chosen by the mode 00's measuring calculation

## 5. CONNECTING TERMINAL BLOCK


<NPN open collector pulse, electric voltage pulse, 90°phase contrast input>



### Caution!

- (1) Check power supply
  1. Be careful not to get a shock while wiring.
  2. Pay attention if the unit is for AC power supply type or DC power supply type
  3. In case of DC power supply, carefully check +, -. Do not connect other way round
- (2) Check the names of terminals and wire them correctly
- (3) Wiring differs depending on the sensors. Refer to the wiring diagram on P11.  
Maximum power supply to sensor is DC12V 100mA (optionally: DC24V 60mA), never over load.  
Wrong wiring might cause damages to sensor or circuit.
- (4) Make sure to tighten the screws on the terminal block
- (5) About BCD output, please refer to "BCD output" on P48  
About BCD input, please refer to "BCD input" on P49
- (6) Sensor's power source should not be used for other usage.

### <Sinusoidal , sine curve, line receiver input>




### Caution!


- (1) Check power supply
  1. Be careful not to get a shock while wiring.
  2. Pay attention if the unit is for AC power supply type or DC power supply type
  3. In case of DC power supply, carefully check +, -. Do not connect other way round
- (2) Check the names of terminals and wire them correctly
- (3) Wiring differs depending on the sensors. Refer to the wiring diagram on P11.  
Maximum power supply to sensor is DC12V 100mA (optionally: DC24V 60mA), never over load.  
Wrong wiring might cause damages to sensor or circuit.
- (4) Make sure to tighten the screws on the terminal block
- (5) About BCD output, please refer to "BCD output" on P48  
About BCD input, please refer to "BCD input" on P49
- (6) With line receiver input(L1,L2) type, terminal block #9 and #10 will be input terminal.  
So alarm output OUT1 and OUT2 cannot be used.
- (7) Sensor's power source should not be used for other usage.

<Connection diagrams for each sensor>


A. DC three wire style pulse sensor




B. DC two wire style pulse sensor




C. Contact output sensor




D. 90° phase contrast input




E. Sinusoidal /Sine curve input




F. Line receiver input



G. Three wire current modulated pulse sensor




H. Two wire current modulated pulse sensor




## 6. FORMAT OF INPUT CIRCUIT


### (1) Sensor input: NPN open collector pulse input or voltage contact input



### (2) Sensor input : Electric pulse input




### (3) Reset/ External input (NPN open collector pulse input)




## 7. FORMAT OF OUTPUT CIRCUIT

(1) Alarm input (OUT1/OUT2): NPN Open collector pulse output




(2) Alarm output (OUT3/ OUT4) : PhotoMOS relay output





## 8. SETTING UP THE DIP SWITCH

Fig. 20




### Setting up the DIP Switch

Dip switch setting can switch mode from input respond frequency, NPN open collector pulse input and electric pulse input

Table 1

|                                                  | B. IN |     | A. IN |     | B.IN | A.IN |                         |
|--------------------------------------------------|-------|-----|-------|-----|------|------|-------------------------|
|                                                  | 1     | 2   | 3     | 4   | 5    | 6    |                         |
| max. link ejecting frequency 0.01Hz-50Hz (LOW)   | ON    | OFF | OFF   | ON  |      |      |                         |
| max. link ejecting frequency 0.01Hz-1kHz (MID)   | OFF   | ON  | ON    | OFF |      |      |                         |
| max. link ejecting frequency 0.01Hz-10kHz (HI)   | OFF   | OFF | OFF   | OFF |      |      |                         |
| max. link ejecting frequency 0.01Hz-120kHz (OP.) | OFF   | OFF | OFF   | OFF |      |      |                         |
| NPN Open Collector Pulse Input                   |       |     |       |     | ON   | ON   |                         |
| Voltage Pulse Input                              |       |     |       |     | OFF  | OFF  | black shows the setting |

- (1) Dip switch can be found from the slit on the right side's corner of the main body. (Ref. Fig. 20)  
If it is not convenient to set, pull out the PCB from the case and do the setting.
- (2) Following three kinds of input type has to be used with the factory preset mode;  
Sinusoidal input(V3),sine curve input(N) and line receiver input(L1, L2).
- (3) For 90°phase contrast input (RE)type,  
make sure to keep the factory preset mode (HI) for both A/B inout for respond frequency.
- (4) Dip switch setting must be done by the combinations shown on the above chart.  
The usage of the combination which is not indicated above might cause some error.



## 10. INITIAL VALUE AND INITIALIZATION

If the special request was made prior to shipment, initial value is set as required.  
Without the request, initial value is set as below.

### Set value for each mode

| Mode # |    | initial value |   |   |   | memo |   |   |  |
|--------|----|---------------|---|---|---|------|---|---|--|
| A      | B  | C             | D | E | F |      |   |   |  |
| 0      | 0. | 0             | 0 | 0 | 0 |      |   |   |  |
| 0      | 1. | 1             | 0 | 0 | 0 |      |   |   |  |
| 0      | 2. | 3             | 0 | 0 | 0 |      |   |   |  |
| 0      | 3. | 1             | 0 | 0 | 0 |      |   |   |  |
| 0      | 4. | 3             | 0 | 0 | 1 |      |   |   |  |
| 0      | 5. | 0             | - | - | 0 |      | - | - |  |
| 0      | 6. | 0             | 0 | - | 0 |      |   | - |  |
| 0      | 7. | 1             | 3 | 1 | 3 |      |   |   |  |
| 0      | 8. | 0             | - | 0 | 0 |      | - |   |  |
| 0      | 9. | -             | 0 | 1 | 4 | -    |   |   |  |
| 1      | 0. | 0             | 0 | 0 | 0 |      |   |   |  |
| 1      | 1. | 1             | 0 | 0 | 0 |      |   |   |  |
| 1      | 2. | 0             | - | 0 | 0 |      | - |   |  |
| 1      | 3. | 0             | - | 0 | 1 |      | - |   |  |

### Each preset value

|          | initial value |   |   |   |   |   | memo |
|----------|---------------|---|---|---|---|---|------|
| PRESET A | 9             | 9 | 9 | 9 | 9 | 9 |      |
| PRESET B | 9             | 9 | 9 | 9 | 9 | 9 |      |

### Display offset value

|          | initial value |   |   |   |   |   | memo |
|----------|---------------|---|---|---|---|---|------|
| OFFSET 1 | 0             | 0 | 0 | 0 | 0 | 0 |      |
| OFFSET 2 | 0             | 0 | 0 | 0 | 0 | 0 |      |

### Mode protect setting value

| Mode protect setting value | initial value |  |  |  |  |  | memo |
|----------------------------|---------------|--|--|--|--|--|------|
|                            | L - OFF       |  |  |  |  |  |      |

### Initialization

Initialization can be done by turning the power on while pressing ENT key.  
After the initialization, set value will be as chart 2, 3, 4 and 5.  
calculation holding data and batch count data will be set as ZERO.




### Caution

Initialization makes every current set value to be reset. Record the current value prior to the initialization.

- \* If the internal computer has interference due to some external factors such as noise, follow the above steps and do the initialization, then set the value as required.

## 11. CONTENTS OF EACH MODE AND SETTING METHOD

### 1. Key operations for each mode setting

|                                                                                                                                                                       | Display                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Operation procedure.                                                                                                                                                                                                                                                        |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|  +  | <div style="display: flex; justify-content: space-around;"> <span>A</span><span>B</span><span>C</span><span>D</span><span>E</span><span>F</span> </div> <div style="display: flex; justify-content: space-around;"> <span>0</span><span>0.</span><span><b>0</b></span><span>0</span><span>0</span><span>0</span> </div>                                                                                                                                   | Press shift key more than 2seconds while pressing the mode key.<br>Display A/B will show [00] and mode [00] will be applied.                                                                                                                                                |
|                                                                                      | <div style="display: flex; justify-content: space-around;"> <span>A</span><span>B</span><span>C</span><span><b>D</b></span><span>E</span><span>F</span> </div> <div style="display: flex; justify-content: space-around;"> <span>0</span><span>0.</span><span>0</span><span><b>0</b></span><span>0</span><span>0</span> </div> <div style="text-align: center;">  </div> | Change the position of flashing digit.<br>One hit makes 1digit move right hand side.                                                                                                                                                                                        |
|                                                                                      | <div style="display: flex; justify-content: space-around;"> <span>A</span><span>B</span><span>C</span><span><b>D</b></span><span>E</span><span>F</span> </div> <div style="display: flex; justify-content: space-around;"> <span>0</span><span>0.</span><span>0</span><span><b>0</b></span><span>0</span><span>0</span> </div> <div style="text-align: center;">  </div> | Change the value of flashing digit.<br>One hit makes the value bigger by 1.<br><div style="text-align: center;">  </div> Some digit might not go up til 9 depending on the setting item.  |
|                                                                                      | <div style="display: flex; justify-content: space-around;"> <span>A</span><span>B</span><span>C</span><span><b>D</b></span><span>E</span><span>F</span> </div> <div style="display: flex; justify-content: space-around;"> <span>0</span><span>0.</span><span>0</span><span><b>0</b></span><span>0</span><span>0</span> </div> <div style="text-align: center;">  </div> | Change the value of flashing digit.<br>One hit makes the value smaller by 1.<br><div style="text-align: center;">  </div> Some digit might not go up til 9 depending on the setting item. |
|                                                                                    | <div style="display: flex; justify-content: space-around;"> <span>A</span><span>B</span><span>C</span><span>D</span><span>E</span><span>F</span> </div> <div style="display: flex; justify-content: space-around;"> <span>0</span><span>1.</span><span>1</span><span>0</span><span>0</span><span>0</span> </div> <div style="text-align: center;">  </div>             | Change the mode number. One hit chooses one mode further. In total, there are 13 modes.<br><div style="text-align: center;">  </div>                                                    |
|                                                                                    |                                                                                                                                                                                                                                                                                                                                                                                                                                                           | Register the set value. After finishing the setting,register setting with this key. After registration, measurment display will appear.                                                                                                                                     |
|                                                                                    |                                                                                                                                                                                                                                                                                                                                                                                                                                                           | Return to measurement display without registering the set value.                                                                                                                                                                                                            |

#### Caution

- Do not turn off the power while registering the set value  
(from pressing ENT until return to measurment display)
- Turn OFF the mode protect while undergoing mode setting.  
With activating mode protect, set value cannot be changed.  
For more details of mode protect function, refer to P45.

---

## 2. Which mode to be set

1. Set the multiplying factor per one input signal.
  - Mode 01(P.22)    A in1 Setting of scaling data (converter)
  - Mode 02(P.23)    A in1 Setting of EXP value and frequency divider.
  - Mode 03(P.24)    B in1 Setting of scaling data (converter)
  - Mode 04(P.24)    B in1 Setting of EXP value and frequency divider.
2. About calculation and measurement method
  - Mode 00 (P.19) setting of calculation measurement method
  - \* This setting is mandatory when RE option is chosen.
  - Mode 08 (P.31-33) setting of overscale display
3. About alarm output (OUT1-4)
  - Mode 05 (P.25-27)    Setting of alarm output 1
  - Mode 06 (P.28-29)    Setting of alarm output 2
  - Mode 07 (P.30)        Setting of alarm output 3
  - For the method of setting preset value, refer to P.43
4. About analog output (AV/AI option)
  - Mode 10 (P.36-37)    Analog output : setting of output style, output digit, reverse output, and output display
  - Mode 11 (P.38-39)    Analog output : setting of the display value at the maximum output
5. About the display
  - (1) Display after the decimal point
    - Mode 00 (P.19) Display 1 : position of decimal point Display 2 : setting of decimal point position
  - (2) Clear the display
    - Mode 08 (P.31-33) Setting of blank display
  - (3) Change the arithmetic measurement display value after reset
    - setting of display offset (P.44)
  - (4) Clear the last measurement data while the power is on
    - Mode 09 (P.34- 35) Reset mode while the power is on
  - (5) Clear Display 1 or 2 while resetting
    - Mode 09 (P.34-35) selection of reset display
  - (6) Switch between display 1 and 2 by key input
    - Mode 00 (P.19) Display selection
  - (7) Switch between display 1 and 2 by external input
    - Mode 08 (P.31-33) selection of external input functions
6. About other functions
  - (1) About usage of external output (forbidden, hold, lapcount, display switch)
    - Mode 08 (P.31-33) selection of external input functions
  - (2) About reset key action
    - Mode 09 (P.34-35) reset key action mode
  - (3) Protect mode setting value
    - Mode protect function (P.45)
  - (4) Output display value by BCD (B option)
    - Mode 12 (P.40-41) Setting of BCD output
  - (5) Input preset value by BCD (BI option)
    - Mode 13 (P.42-43) setting of BCD input

### 3. Mode content and set value

Mode#

Setting of display selection, measurement calculation, decimal position of display 1 and decimal position of display 2

0 0

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 0. | 0 | 0 | 0 | 0 |

Display 2 decimal point position

0 : 0  
1 : 0.0  
2 : 0.00  
3 : 0.000

Display 1 decimal point position

0 : 0  
1 : 0.0  
2 : 0.00  
3 : 0.000

Measurement calculation method

| No. | Display 1 | Display 2 |
|-----|-----------|-----------|
| 0   | A - B     | A         |
| 1   | A + B     | A         |
| 2   | A or -A   | ----      |
| 3   | A - B     | B         |
| 4   | A         | B         |
| 5   | A         | -B        |
| 6   | - A       | -B        |

\* Choose from 90°phase contrast input (RE)type, "0" or "3"

Display selection

0: Display 1 (fixed)  
1: Display 2 (fixed)  
2: Display 1/ Display 2 (selectable)

#### <Display selection>

Select from switching display or keeping it as fixed when pressing ENT key on the measurement display.

#### <Measurement calculation method>


|          |                                                                                                                                                            |
|----------|------------------------------------------------------------------------------------------------------------------------------------------------------------|
| A        | Add the signal which was entered to A input                                                                                                                |
| - A      | Deduct the signal which was entered to A input                                                                                                             |
| B        | Add the signal which was entered to B input                                                                                                                |
| - B      | Deduct the signal which was entered to B input                                                                                                             |
| A - B    | Add the signal which was entered to A input and deduct the signal which was entered to B input.                                                            |
| A + B    | Add the signals which were entered to A and B input                                                                                                        |
| A or - A | Add the signal which was entered to A input when B input was in LOW level and deduct the signal which was entered to A input when B input was in HI level. |




#### <Decimal point position>

Setting the display digits which are after the decimal point.

[ Measurement calculation method]

0 : A-B (individual add-subtract input)



**0 : A-B (90° phase contrast input with RE option)****1 : A+B****2 : A or -A**

When B input is electric pulse input, count will be UP (adding)  
and Down (subtraction) will be reversal.

**<Caution>**

When this calculation method is chosen, do not set alarm display selection  
and display 2 of analog output display selection  
If display 2 is set, it might output irrespective of display.



**0 1**

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 1. | 1 | 0 | 0 | 0 |

4digits value 0001 - 9999  
( Do not set "0000" )

Function as scaling data (converter) for integrating measurement.  
By setting the 4digit value and EXP value which is set by [Mode 02],  
scaling factor per 1 signal can be set until  $1 \times 10^{-9}$  - 9999.

**[example]**

Want to display integrating value as "L" using the flow sensor which is 2.5ml per 1 pulse.

$$2.5 \text{ mL} \rightarrow \frac{0.0025 \text{ L}}{\text{Adjust the preferred unit (L)}} = \frac{2500}{\text{4digits value}} \times \frac{10^{-8}}{\text{EXP value}}$$


Mode 01

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 1. | 2 | 5 | 0 | 0 |

Mode 02

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 2. | 6 | * | * | * |

02

**[ EXP value]**

Setting of the ten's power (minus).

Combine with [Mode 01] and set the scaling data (converter).

**[Frequency divider]**

Set the input pulse. If the pulse per rotation is known, input that value.

The calculation will be more accurate.

**<caution>**

When using frequency divider, display turn to be ZERO or display offset value when reset.


However, the accumulated frequency divider value will not be erased.

**[example]**

When the frequency divider is set to 003(1/3), outcome will be as follows;

3 pulse output per 1 rotation, and 0.5m roller sending per 1 rotation.

It is not clear even if reset.



Using only scaling data (converter) might cause some error. In that case, divide the input.

Setting should be as follows

|         |   |    |   |   |   |   |
|---------|---|----|---|---|---|---|
| Mode 01 | 0 | 1. | 5 | 0 | 0 | 0 |
| Mode 02 | 0 | 2. | 4 | 0 | 0 | 3 |

$$0.5 = 5000 \times 10^{-4}$$

Frequency divider should be 3 as 1rotation produces 3pulse output.

With this, as sensor rotate once, integrated value will increase by 0.5.

**< Caution>**

In case of 90°phase contrast input, same setting should be applied to A/B input scaling data, EXP value, and frequency divider.

Mode# **B Input: Setting of scaling data (converter)**

03

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 3. | 1 | 0 | 0 | 0 |

4digits value 0001 - 9999  
( Do not set "0000" )

Setting procedure is same as "Mode 01 [A input: Setting of scaling data (converter)]"

Mode# **B Input: Setting of EXP value and frequency divider**

04

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 4. | 3 | 0 | 0 | 1 |

frequency divider : 3digits 1/1 - 1/999  
(000 to be 1/1000)

EXP value ( $10^{-n}$ )      n = 0 - 9

Setting procedure is same as "Mode 02[A input: Setting of EXPvalue and frequency divider]"

0 5

\* Model with optional line receiver input(L1,L2) cannot output as output terminal will be input terminal <only LED can react>

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 5. | 0 |   |   | 0 |

**Selection of preset action**

- 0 : plus side 2 stages preset action
- 1 :  $\pm$ each stage preset action
- 2 : batch count action (only the setting with automatic reset)
- 3 : plus 1 stage and secondary output action  
(only the setting without re-output)

**Display selection**

- 0 : Display 1
- 1 : Display 2

**<Caution>**

Do not select display 2 when selecting A or -A with Mode 00 [measurement calculation method]

**[Display selection]**

Display 1 : Output against Display 1  
Display 2 : Output against Display 2

**[Preset action selection]**

setting of output action

For the timing chart and setting condition,  
refer to [output timing for preset action and setting condition]


- \* when changing setting, do so as display offset value  
and preset value will be included in setting condition.

**<Caution>**

When Mode 05 to 07 are changed, DO NOT FORGET TO RESET BEFORE STARTING MEASURING.

## Output timing for preset action and setting condition

### 0: Plus side 2stages preset action




#### Setting name (contents)

PRESET A: 1stage setting value  
 PRESET B: 2nd stage setting value  
 OFFSET: Display value when reset (display offset value)

#### Setting condition

UP: Offset =0, OFFSET < PRESET A < PRESET B  
 DOWN: PRESET B =0, PRESET B < PRESET A < OFFSET

### 1: ±Each 1stage preset action



#### Setting name (contents)


PRESET A: Plus side setting value  
 PRESET B: Minus side setting value  
 OFFSET: Display value when reset (display offset value)

#### Setting condition (set each item as follow)

UP/DOWN: OFFSET=0, PRESET B < Offset < PRESET A

## Output timing for preset action and setting condition

### 2: Batch count action



With this preset action, display will show batch count while pressing "Shift Key"




#### Setting item (Contents)

Preset A: Setting value of No.1 counter Preset B: setting value of batch count display  
Offset: Reset display value (display offset setting value)

#### Setting condition (set each item as follow)

UP: offset=0, Offset < Preset A, Preset B > 0  
DOWN: Preset3=0 Offset > Preset A, Preset B > 0

### 3: Plus 1stage and secondary output action



#### Setting item (Contents)

Preset A: Pulse setting value Preset B : Retardation setting value  
Offset: Reset display value (display offset setting value)

#### Setting condition (set each item as follow)

UP: offset=0, Offset < Preset A, 99.9 ≥ Preset B ≥ 0  
DOWN: Preset3=0 Offset > Preset A, 99.9 ≥ Preset B ≥ 0

0 6

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 6. | 0 | 0 |   | 0 |

**Re-output selection**

0: Without re-output  
1: With re-output

**<Caution>**

This selection will be invalid when following mode is selected;  
With automatic reset, batch count action,  
puls 1 stage and secondary action

**Automatic reset selection**

0= without automatic reset  
1= with automatic reset

**<Caution>**

This selection will be invalid when following mode is selected;  
±each 1 stage preset action and batch count action

**UP/DOWN selection**

0: Up  
1: Down

**<Caution>**

This selection will be invalid when ±each 1 stage preset action  
is selected.

**[UP/DOWN selection]**

UP- Alarm will be activated when Display value  $\geq$  Preset value (upper limit output action)

DOWN- Alarm will be activated when Display value  $\leq$  Preset value (lower limit output action)

\* Display offset value and preset value should be included in setting condition when  
setting is to be changed.

**[Automatic reset selection]**

Without automatic reset- display value will not go back to display offset value when the output  
conditions are met.

With automatic reset- display value will go back to display offset value when the output  
conditions are met.

Actions of each preset are as follows;

**(1) Plus side 2stages preset action**

UP: reset - Preset B  $\geq$  display value - display value = display offset value - recount

DOWN: reset - Preset B  $\leq$  display value - display value = display offset value - recount

**(2) Batch count action**

UP: reset - display value = display offset value - Preset A  $\geq$  display value -

display value = display offset value - batch count display plus 1 - recount

DOWN: reset - display value = display offset value - Preset A  $\leq$  display value -

display value = display offset value - batch count display plus 1 - recount

**(3) Plus side 1stages secondary output action**

UP: reset - Preset A  $\geq$  display value - display value = display offset value - recount

DOWN: reset - Preset A  $\leq$  display value - display value = display offset value - recount

**<Caution>**

Output mode is going to be 1 shot output when plus side 2 stages preset action or plus 1 stage  
and secondary output action is selected and add automatic reset function.

**[Re output selection]****- without re-output -**

Sequence output : once it is out, "output off" will not be activated even if it is not within tolerance (condition)

"output off" will be on when reset input and automatic reset functions

1 shot output : 1 shot of pulse with set duration will be output when output conditions are met.  
After 1shot, no output will be made even if the output conditions are met.  
Reset input or automatic reset can activate the output.

**- with re-output -**

Sequence output : Output will be ON when output only if condition are met.  
However, re-output will be invalid when plus side 2 stages preset action (with automatic reset) is chosen

1 shot output : 1 shot of pulse with set duration will be output when output conditions are met.

**<Caution>**

When plus side 2 stages preset action(with automatic reset) and 1stage and secondary output action is chosen,  
re-output will be invalid no matter what re-output setting is made.



07

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 7. | 1 | 3 | 1 | 3 |

**OUT 2&4 Duration of 1shot output**

|     |        |     |        |
|-----|--------|-----|--------|
| 0 : | 10 ms  | 5 : | 250 ms |
| 1 : | 20 ms  | 6 : | 500 ms |
| 2 : | 50 ms  | 7 : | 750 ms |
| 3 : | 100 ms | 8 : | 1 sec  |
| 4 : | 200 ms | 9 : | 2 sec  |

**<Caution>**

Output 2&4's LED flashing might not be visible when 10ms is chosen although

**Out 2&4 Output mode**

0 : sequence output  
1 : 1shot output

**OUT 1&3 Duration of 1shot output**

|     |        |     |        |
|-----|--------|-----|--------|
| 0 : | 10 ms  | 5 : | 250 ms |
| 1 : | 20 ms  | 6 : | 500 ms |
| 2 : | 50 ms  | 7 : | 750 ms |
| 3 : | 100 ms | 8 : | 1 sec  |
| 4 : | 200 ms | 9 : | 2 sec  |

**<Caution>**

Output 1&3's LED flashing might not be visible when 10ms is chosen although

**Out 1&3 Output mode**

0 : sequence output  
1 : 1shot output

**[ OUT1&3 or OUT 2&4 output mode]**

Sequence : Output will be activated when the conditions are met.

If it is beyond tolerance (condition), output will be OFF.

1 shot : 1 shot of pulse with set duration will be output when output conditions are met.

**[ OUT 1&3 or OUT 2&4 duration of 1shot output]**

Set the duration of 1shot output. (output margin is  $\pm 2$ ms)

08

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 8. | 0 |   | 0 | 0 |

**Overscale display**

- 0 : 3rounds stop
- 1 : Endless
- 2 : Up key to show numbers of time go over (upper 2digits)


**External input function**

- 0 : Banned input
- 1 : Hold input
- 2 : Lap count input
- 3 : Display switch input

**Blank display**

- 0 : No Blank display (Display measured value)
- 1 : Blank display (No Display measured value)

**[Blank display]**

Set whether to display measured value or not. Only the measured value will blink when "blank display" is set.  
Alarm output LED and hold LED will function normally.

**[External input function]**

Setting the function of terminal block 2 to 3. When it is ON, hold LED will blink.

- 0 : Banned input - Bann the sensor input while ON
- 1 : Hold input - Keep displaying the current value while ON (blink when it functions) measurement is proceeding internally (overscale LED will be kept as well)
- 2 : Lap count input - Once it is ON, current value will be kept and blinking. Measurement is reset and start measureing again. Another ON will display the value calculated internally.
- 3 : Switch display input - Display 1 and Display 2 are switched at every ON.



0 8

**[ Overscale display ]**

select the display method when value become more than "999999" or less than "-999999".

**0 : 3round stop**


Value blinks when value exceed "999999" or go below "-999999" for the third time.

**1 : Endless**

**0 : Overscale times (upper 2digits) display**

Display will show how many times measurement went overscale while pressing Up key.

Over LED will disappear while pressing Up key and displaying overscale, but if it exceed 99times, over LED will blink.



Zero surpress: delete "0" in the upper digits.

(sample) Displaying 100

Display 0 0 0 1 0 0 ← Without Zero surpress

↓ Surpressing Zero

Display 1 0 0

09

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 0 | 9. |   | 0 | 1 | 4 |

### Selecting of Reset Display

- 0 : Display1, Display2 (Key input, movement Terminal Board Input)
- 1 : Current Display (Key input, movement Terminal Board Input)
- 2 : Display1 (Key input, movement Terminal Board Input)
- 3 : Display2 (Key input, movement Terminal Board Input)
- 4 : Key Input: Current Display,  
Terminal Board Input: Display1, Display2

### Action Mode of Reset key

- 0 : Not Reset
- 1 : Reset in a bit
- 2 : Need pushing key for 1 seconds
- 3 : Need pushing key for 2 seconds

### Reset Node in Power ON

- 0 : Not Reset
- 1 : Reset

### Reset Node in Power ON


Select record measured value at last time or delete measured value at last time in Power ON

- 0 : You begin measuring from last measured value.
- 1 : The last measured value is deleted and You begin measuring from display offset value.


### Action Mode of Reset Key

- 0 : Not Reset


- 1 : Reset in a bit



- 2 : Need pushing key for 1 seconds



3 : Need pushing key for 2 seconds

**Select of Reset Display**

Display1, Display2 : The integrated value is returned to display offset value.  
All alarms are canceled.

Current Display : The integrated value is returned to display offset value.  
The alarms of current display are canceled.

Display1 : The integrated value of display1 is returned to display offset value.  
The alarms of display1 are canceled.

Display2 : The integrated value of display2 is returned to display offset value.  
The alarms of display2 are canceled.

1 0

Need set it on the AV3-5/A1 option

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 1 | 0. | 0 | 0 | 0 | 0 |

**Analog Output**

- 0 : Synchronizing with indicated value
- 1 : Synchronizing with measurement

**Output Digits Selection**

- 0 : Right      4 digits (CDEF)
- 1 : Center    4 digits (BCDE)
- 2 : Left      4 digits (ABCD)

**Reverse Output Selection**

- 0 : Standard    (0-10V, 0-5V, 1-5V, 4-20mA)
- 1 : Reverse    (10-0V, 5-0V, 5-1V, 20-4mA)

**Analog Output Display Selection**


- 0 : Display1
- 1 : Display2

**Select of the Analog Output Display**

Select analog output display1 or analog output display2.

**Select of the Reverse Output**

Analog output is reversed.

**Select of the Output Digits****Analog Output**

- 0 : Synchronizing with indicated value  
Analog output to indicated value
- 1 : Synchronizing with measurement  
Analog output to result of internal arithmetic

1 1

\* This setting is necessary when AV3-5/AI option is chosen.

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 1 | 1. | 1 | 0 | 0 | 0 |

Display 0001 - 9999  
( Do not set "0000" )

### [Setting the indicated value of Max. Analog output]

Setting the indicated value of Max. Analog output.

Set 4 digits, and disregard the decimal point at that time.

### [example 1]

Analog output is AV5(0-10V), Setting of maximum output when display is \_\_ 1 0 0 0

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 1 | 0. |   |   | 0 |   |

Mode 10

E : 0

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 1 | 0. | 1 | 0 | 0 | 0 |


Mode 11

C - F (Display is "1000" when output is maximum)

### <Caution>

Analog output is a absolute value of display value.


Output is as shown in the figure below.



### [example 2]

Output digits is 4 digits of left, Display is 2000 when maximum analog output, Range is DC0-10V.

It is shown in the figure below when these conditions,





1 2

\* This setting is necessary when B option is chosen.

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 1 | 2. | 0 |   | 0 | 0 |

**BCD Data Output Logic**

- 0 : Data (+), TI signal / Parity (+)
- 1 : Data (-), TI signal / Parity (+)
- 2 : Data (+), TI signal / Parity (-)
- 3 : Data (-), TI signal / Parity (-)

**BCD Data Output Timing**

- 0 : TI signal is used
- 1 : Request signal is used

**BCD Output Display selection**

- 0 : Display 1
- 1 : Display 2

**Select of the BCD Output Display**

Select BCD output display1 or analog output display2.

**BCD Data Output Timing**

- 0 : TI signal is used  
Capture prohibition signal
- 1 : Request signal is used  
The update of data is demanded.

**BCD Output Display selection**

Setting of the "Output display data", "TI signal", "Parity logic"

Positive Logic : The collector of output transistor and emitter are conducting.

Negative Logic : The collector of output transistor and emitter are not conducting.

| Logic          | Display Value | Bit Data |   |   |   | NPN Open Collector Output |     |     |     |
|----------------|---------------|----------|---|---|---|---------------------------|-----|-----|-----|
|                |               | 8        | 4 | 2 | 1 | 8                         | 4   | 2   | 1   |
| Positive Logic | 1             | 0        | 0 | 0 | 1 | OFF                       | OFF | OFF | ON  |
| Negative Logic | 1             | 0        | 0 | 0 | 1 | ON                        | ON  | ON  | OFF |

1 3

\* This setting is necessary when BI option is chosen.

| A | B  | C | D | E | F |
|---|----|---|---|---|---|
| 1 | 3. | 0 |   | 0 | 1 |

**BCD Data Input Logic**

0 : Hi Active (Each input terminal and GND are open.)

1 : Low Active (Each input terminal and GND are open.)

**Latch Signal Input Logic**

0 : Latch on short

1 : Latch on open

**BCD Data Input selection**

0 : Stall

1 : PRESET A

2 : PRESET B

**Select of the BCD Data Input**

Select BCD input for which preset.

**Latch Signal Input Logic**

Data is not input when latch signal is input.

0 : Latch on short - Data is not input when latch signal pin and GND are short.

1 : Latch on open - Data is not input when latch signal pin and GND are open.

**BCD Data Input Logic**

Setting of the Logic of BCD Data which is inputted.

0 : Hi Active - Data is input when each pin of input data and GND are open.

1 : Low Active - Data is input when each pin of input data and GND are short.

## 12. SETTING OF PRESET VALUE

Do the following operation for setting of the preset value of each alarm output.




Setting range is "-99999 - 999999.

Preset B's setting range is "0000.0 - 00099.9" when output is 1 stage and secondary output.

Decimal point synchronizes with setting of the "Mode00"(ref.P19).

Initial value is "999999"

Refer to "Mode05","Mode06","Mode07"(from P25 up) for setting of the alarm output action(OUT1&3, OUT2&4).

| Operation Key                                                                       | Display                                                                | Operation                                                                                                                                                                                                                                                                                                  |
|-------------------------------------------------------------------------------------|------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|    | A B C D E F<br>9 9 9 9 9 9<br>OUT1 OUT2 OUT3 OUT4<br>● ○ ● ○           | Press Mode key more than 2 seconds.<br>OUT1&3's LED light, then PRESET of OUT1&3 is called.                                                                                                                                                                                                                |
|                                                                                     | A B C D E F<br>9 9 9 9 9 9<br>OUT1 OUT2 OUT3 OUT4<br>○ ● ○ ●           | <br>PRESET Value is switched pushing Mode Key.                                                                                                                                                                           |
|    | A B C D E F<br>9 → 9 → 9 → 9 → 9 → 9<br>OUT1 OUT2 OUT3 OUT4<br>○ ● ○ ● | Change to right the position of flashing digit.<br>One hit makes 1digit move right hand side.                                                                                                                                                                                                              |
|   | A B C D E F<br>9 9 9 9 9 9<br>OUT1 OUT2 OUT3 OUT4<br>○ ● ○ ●           | Change the value of flashing digit.<br>One hit makes the value bigger/smaller by 1.<br><br>Also, The indicator-A displays "-".<br> |
|  | A B C D E F<br>9 9 9 9 9 9<br>OUT1 OUT2 OUT3 OUT4<br>○ ● ○ ●           | Register the set value. After finishing the setting,register setting with this key. After registration, measurment display will appear.                                                                                                                                                                    |
|  |                                                                        | Return to measurement display without registering the set value.                                                                                                                                                                                                                                           |

### Caution

1. Do not turn off the power while registering the set value  
(from pressing ENT until return to measurment display)
2. Mode Protect does not function.
3. Reset it before starting measurement when PRESET Value is changed.

### 13. SETTING OF DISPLAY OFFSET

Setting of display in reset. Such as when setting of display offset "001000", the display in reset is "1000" and measurement begin from "1000". If you begin to measurement from "0", setting of display offset "000000".

The following table refer to key operation to setting of display offset.

The setting range is "-99999 - 999999".

(Setting of the decimal point is connected to [Mode 00] in P19.

Initial value is "000000"

| Operation Key                                                                                                                                                                | Display                                                       | Operation                                                                                                                                                                                   |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|                                                                                             | <div> A B C D E F<br/> 0 0 0 0 0 0<br/> D1 D2<br/> ● ○ </div> | Press Mode key and Up key more than 2seconds. D1LED's LED light, then Display Offset of D1 is called.                                                                                       |
|                                                                                             | <div> A B C D E F<br/> 0 0 0 0 0 0<br/> D1 D2<br/> ○ ● </div> | <div>→ D1 → D2 → D1 → D2 →</div><br>PRESET Value is switched pushing Mode Key.                                                                                                              |
|                                                                                             | <div> A B C D E F<br/> 0 → 0 → 0 → 0 → 0<br/> ↑ </div>        | Change to right the position of flashing digit. One hit makes 1digit move right hand side.                                                                                                  |
| <br>or<br> | <div> A B C D E F<br/> 0 1 0 0 0 0 </div>                     | Change the value of flashing digit. One hit makes the value bigger/smaller by 1.<br><div>⇐ 0 ⇐ 1 ⇐ ... ⇐ 9</div><br>Also, The indicator-A displays "-".<br><div>⇐ 0 ⇐ 1 ⇐ ... ⇐ 9 ⇐ -</div> |
|                                                                                           | <div> A B C D E F<br/> 0 1 0 0 0 0 </div>                     | Register the set value. After finishing the setting,register setting with this key. After registration, measurment display will appear.                                                     |
|                                                                                           |                                                               | Return to measurement display without registering the set value.                                                                                                                            |
|                                                                                           | <div> A B C D E F<br/> 1 0 0 0 0 </div>                       | Push reset key after register to the display offset value, and display the setting of display offset. Measurement begin from this value.                                                    |

#### Caution

1. Do not turn off the power while registering the set value  
(from pressing ENT until return to measurment display)
2. Mode Protect does not function.
3. Reset it before starting measurement when Display Offset Value is changed.

## 14. MODE PROTECT FUNCTION

---

If turn on the mode protect function, up key and down key can not be inputed in setting mode, and can not be changed setting value.

**Mode protect function is OFF at shipping.**

### Operation of Mode protect function

- (1) Display is selected to the measurement display.  
\* Mode protect function can not be called during the setting of Mode/Preset/Display offset.

- (2) Press down key more than 2seconds.

- (3) Current mode protect is displayed after 2 seconds.

Mode protect "ON"

| A | B | C | D | E | F |
|---|---|---|---|---|---|
|   | L | - | O | N |   |

Mode protect "OFF"

| A | B | C | D | E | F |
|---|---|---|---|---|---|
|   | L | - | O | F | F |

- (4) In addition, if press down key more than 8seconds, mode protect function is changed.  
\*\*"ON" changes into "OFF" and "OFF" changes into "ON".
- (5) Stop press down key, and return to measurement display.

### Caution

Mode protect function is invalid in setting of Preset value, Display offset value.

Specification(AV3-5/AI) of product is being adjusted accurately by us.  
Do not touch excluding the emergency.

### Methode of adjustment

- (1) Call test mode by turning on while pushing Mode key.
- (2) Call the analog output test by pushing Mode key at few times.  
( Refer to "Setting menu" on page15 )
- (3) Adjust "Span-volume/Zero volume" to become the following values.  
(Adjust Span-volume first.)

#### Voltage output : AV3 type

| Display | Voltage |                    |
|---------|---------|--------------------|
| 0       | 1V      | Turn "Zero volume" |
| 10      | 5V      | Turn "Span volume" |

#### Voltage output : AV4 type


| Display | Voltage |                    |
|---------|---------|--------------------|
| 0       | 0V      | Turn "Zero volume" |
| 10      | 5V      | Turn "Span volume" |

#### Voltage output : AV5 type

| Display | Voltage |                    |
|---------|---------|--------------------|
| 0       | 0V      | Turn "Zero volume" |
| 10      | 10V     | Turn "Span volume" |

#### Voltage output : AI type

| Display | Voltage |                    |
|---------|---------|--------------------|
| 0       | 4mA     | Turn "Zero volume" |
| 10      | 20mA    | Turn "Span volume" |



## 16. SENSITIVITY SETTING OF SINUSOIDAL INPUT AND SINE CURVE INPUT


---

The specification of each product is being adjusted accurately by us before shipping.  
Do not touch excluding the emergency.  
If you adjust sensitivity, we do not take the responsibility.

Sinusoidal input type : AC0.8 - 80Vp-p  
Sine curve input type : AC0.05 - 20Vp-p

### Method of adjustment


- (1) Remove attachment parts.
- (2) You can see "Sensitivity setting volume" at ellipse's hole on left side of product.  
See and adjust it.




## 17. BCD OUTPUT

1. BCD code is all-digit parallel output at NPN open collector pulse output (DC30V 10mA MAX).
2. Output logic of data can be changed.(Refer to P40)  
 Positive Logic : The collector of output transistor and emitter are conducting.  
 Negative Logic : The collector of output transistor and emitter are not conducting.
3. Take data when TI signals to turning off.  
 logic of TI signal can be changed.(Refer to P40)
4. When this option is selected, D-sub37P male connector (XM2A-3701) and Hood (XM2S-3711) are attached by the addition.


### BCD Output Pin Layout (D-Sub 37P female connector at meter side)



### BCD Output Circuit Diagram (NPN open collector pulse output)



### BCD Output Time Chart







## 18. BCD INPUT

1. BCD code is all-digit parallel input at NPN open collector pulse input.
2. Input logic of data can be changed.(Refer to P42)  
 Hi Active : Each input terminal and GND are open.  
 Low Active : Each input terminal and GND are open.
3. Latch Signal Input  
 Data is not input when latch signal is input.  
 0 : Latch on short - Data is not input when latch signal pin (37pin) and GND are short.  
 1 : Latch on open - Data is not input when latch signal pin (37pin) and GND are open.
4. When this option is selected, D-sub37P male connector (XM2A-3701) and Hood (XM2S-3711) are attached by the addition.

### BCD Input Pin Layout (D-Sub 37P female connector at meter side)




### Taking Data (Latch Signal Input logic is "Latch on short")




## 19. OUTLINE DRAWING

### Outline drawing




### Panel cut dimensions and interval




## 20. TERMINAL BOARD LABEL DRAWING

NPN Open collector pulse  
/ Electric voltage pulse  
/ 90° phase contrast input




Sinusoidal  
/ Sine curve  
/ Line receiver input




[mm]

## 21. UNIT LABEL DRAWING




## 22. PACKING SPECIFICATIONS

DT-601CG (main unit)  
with terminal board cover



Air-Cap packing material



Rubber packing



< ACCESSORY >


D-SUB37PIN (male connector), Hood  
\*B, BI OPTION




Unit label




Poly Bag



Air-Cap packing material



Box




## 23. ABOUT NOISE PROTECTION


Refer to the following if there is problem of electronic noise.

If product has problem that is a display disapper/mis-display, Do the initialization.(Refer to P16)  
Initialization makes every current set value to be reset. Record the current value prior to the initialization.  
And do the following noise protection.


- (1) Do not share power supply and power line directly.  
When you use power line, Use isolation transformer and use secondary.
- (2) Use three core shield line for sensor cord.
- (3) Shorten sensor cord as much as possible.
- (4) It is better not to connect machinery's ground wire with GND of meter.
- (5) Use noise filter if there is a noise from power line. (Refer to following figure.)



- (6) wired method of sensor cord  
When the power cord passes near sensor cord, sensor cord must be wired with single.



- (7) When the noise is generated around product, Use a spark killer.  
Ex: Electromagnetic Contactor, Temperature Controller, Solenoid Valve, Relay, etc. )



## 24. TROUBLE SHOOTING

| No | Problem                                                                                                                      | Check Point                                                                                                                                                                                                  | Measures                                                                                                                                                                                                                                              |
|----|------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1  | The indicator doesn't light.<br>Blank display                                                                                | Is power supply correct?<br>Is not the cord short-circuited?<br><br>Is "1: Blank display" selected<br>in mode10-C?                                                                                           | Confirm wiring.<br>Tighten the terminal screw again.<br><br>Cancel the "Blank Display".<br>(Refer to Page 31)                                                                                                                                         |
| 2  | LED abnormal light<br>Switch abnormal action<br>Abnormal synchronous pulse<br>Relay abnormal output<br>Abnormal analog outpt | Check by test mode.<br>(Refer to Page 15)                                                                                                                                                                    | Do Initialization.<br>(Refer to Page 16)                                                                                                                                                                                                              |
| 3  | The display doesn't change<br>from "0".                                                                                      | Is setting of each mode correct?<br><br>Is the sensor input normal?<br><br>Is the detection distance<br>of proximity sensor normal?<br><br>Are output signal of sensor and<br>input method of meter correct? | Setting value is less than<br>effective viewing area.<br><br>Tighten the terminal screw again.<br>And check by test mode.<br>(Refer to Page 15)<br><br>Confirm flashing sensor light.<br><br>Confirm the specification sheet.<br>(Refer to Page 9-11) |
| 4  | The display disappears.<br>The display becomes twice<br>or more.                                                             | Check influence of spark noise<br>form Electromagnetic switch,<br>Solenoid valve, Relay.                                                                                                                     | Do the noise measures.<br>(Refer to Page 54)                                                                                                                                                                                                          |